

Note-1: Tank body material will be ASTM A 283 GR C / S235 JR (ST 37.2) quality

The membrane connection bolts will be made of reinforced rubber.

All Welds will be continuous unless otherwise stated is not

Not specify the weld thickness, then element will be up to 0.7 (a=0.7x t_{min})

All weld thickness will be not less than 3 mm

All steel components will be sand blasting according to SA 2 1/2 "quality and will be (internal and external surface) painted with 200 microns epoxy

All welds will be tight. Tank bottom will be leakage test

Welding standard : DIN 9112 ; TS-1987 ; ISO -2553-1984

